

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0067:134

Page 1 of 1

CATEGORY: Misc Device/Control Unit Accessories

LISTEE: Siemens Building Technologies Inc., *Fire Safety Div., 8 Fernwood Rd, Florham Park NJ 07932
Contact: Peter Pawchak (973) 593-2662 Fax (973) 593-6652

DESIGN: Models DB4T, DB4TS, DB4F, DB4TF, DB4FS, DB3S, ADB3, ADBX3, DB-HR, DBX3RS, DB-11, DB-X11RS, ADBI60, ADB-11, ADBH-11, ADBX-11 and 8837 detector bases and Model DB-ADPT detector/base adapter. Suitable for use with Models RR2 or RR3 auxiliary relays. Model DB-11 is suitable for use only with Model RR-11 or RR-11F auxiliary relay. Models DB-11 base, ADBH-11 audible base, and DB-HR relay base are intended to be used with Models HFP-11 and HFPT-11 Intelligent Series smoke and heat detectors (CSFM Listing No. 7272-0067:223 and 7270-0067:224). Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. Model DB-11, ADBH-11 and DB-HR may be installed on the ceiling or on the wall.

MARKING: Listee's name or Cerberus Pyrotronics, model number, electrical rating and UL label.

APPROVAL: Listed as detector bases for use with separately listed compatible smoke detector heads and fire alarm control units.

*Rev. 10-28-2002 JEW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

OCTOBER 28, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager